



* *liquide commun = 45 kW*

* *Aspiration négative:*

* *Aspiration positive:*

(Récap): Côté liquide:

0 → 1 : 45 kW [L = 20 m]

1 → 2 : 19,5 kW [L = 10 m; L₀ [10 + 20] = 30 m]

2 → P₁ : 6 kW [L = 3 m; L₀ = 30 + 3 = 33 m]

2 → 3 : 13,5 kW [L = 2 m; L₀ = 30 + 2 = 32 m]

3 → P₂ : 6 kW [L = 7 m; L₀ = 32 + 7 = 39 m]

3 → N₄ : 7,5 kW [L = 10 m; L₀ = 32 + 10 = 42 m]

1 → 4 : 25,5 kW [L = 5 m; L₀ = 20 + 5 = 25 m]

4 → P₃ : 6,8 kW [L = 3 m; L₀ = 25 + 3 = 28 m]

4 → 5 : 19,5 kW [L = 7 m; L₀ = 25 + 7 = 32 m]

5 → P₄ : 6 kW [L = 5 m; L₀ = 32 + 5 = 37 m]

5 → 6 : 13,5 kW [L = 2 m; L₀ = 37 + 2 = 39 m]

6 → P₅ : 6 kW [L = 12 m; L₀ = 39 + 12 = 51 m]

6 → N₂ : 7,5 kW [L = 9 m; L₀ = 39 + 9 = 48 m]